Public Health Inspection
150 Independent Street
Yorkton, SK S3N 0S7
P: 306.786.0600 | F: 306-786-0620

November 13, 2026

RM of Sliding Hills No. 273
PO Box 70
Mikado, SK S0A 2R0
Email: rm273@sasktel.net

Attention LeeAnn Weinbender

RE: Precautionary Drinking Water Advisory – Donwell Well – Facility No. 013625

A **Precautionary Drinking Water Advisory** has been issued by the Saskatchewan Health Authority for the public water supply known as Donwell Well, located at SE 09-30-03 W2M, Rural Municipality of Sliding Hills, in the Province of Saskatchewan. This advisory is being issued due to:

- the presence of coliform bacteria in the water supply (3 orgs /100mL)

This **Advisory** is in effect as of November 13, 2026 and will be in effect until the following conditions are met:

- The well is shock chlorinated, chlorinated water is run through entire distribution system and left for 12-24 hours before flushing out chlorinated water.
- Following the shocking and flushing protocol, two consecutive satisfactory bacteriological results from the system are obtained. These samples are to be collected at least seven days apart.

Please notify all users of the water supply of the Advisory and post the attached poster at any places where the public would have access to the water.

Healthy People, Healthy Saskatchewan

The Saskatchewan Health Authority works in the spirit of truth and reconciliation, acknowledging Saskatchewan as the traditional territory of First Nations and Métis People.

NOTICE OF CONFIDENTIALITY: This information is for the recipient(s) listed and is considered confidential by law. If you are not the intended recipient, any use, disclosure, copying or communication of the contents is strictly prohibited.